



Challenges of Implementing Substation Hardware Upgrades for NERC CIP Version 5 Compliance to Enhance Cybersecurity

J. Matt Cole, PE
 Power Delivery Services
 Sargent & Lundy LLC
 Chicago, IL, USA
 Joesph.m.cole@sargentlundy.com

Abstract—To minimize the vulnerability of the electric power grid to cyberattacks the NERC enacted and enforced cybersecurity standards that continue to evolve as technology and the nature of these threats advance. These Critical Infrastructure Protection (CIP) standards require utilities to meet an aggressive timeline for regulatory compliance. This paper discusses major design challenges faced when upgrading substation equipment for cybersecurity enhancements and, specifically, the hardware improvements implemented for the NERC CIP V5 conversions.

RECENT CYBER ATTACKS AND THREATS (UKRAINE)

- Spear phishing email received with malware 9 months before attack
- All breakers opened at 27 substations
- 103 cities blacked out with another 189 partially out

NERC CIP VERSION 5 REGULATORY STANDARDS


- V5 Deadline delayed from April 1 to July 1, 2016

V5 SUBSTATION DESIGN CHALLENGES


- VLANs not recommended for CCAs and Non-CCAs
- Installing Firewalls, IPS/IDS and EACMS
- Upgrading legacy and obsolete equipment
- Security risks for unsecure dial up devices
- Unanticipated costly equipment upgrades
 - Incompatibility issues/security vulnerabilities with legacy equipment
 - Telecomm Transport Systems
 - Battery/Charger Systems

NERC CIP STANDARDS	TITLE
CIP-002-5.1	BES Cyber System Categorization
CIP-003-5	Security Management Controls
CIP-004-5.1	Personnel & Training
CIP-005-5	Electronic Security Perimeter(s)
CIP-006-5	Physical Security of BES Cyber Systems
CIP-007-5	System Security Management
CIP-008-5	Incident Reporting and Response Planning
CIP-009-5	Recovery Plans for BES Cyber Systems
CIP-010-1	Configuration Change Management and Vulnerability Assessments
CIP-011-1	Information Protection
CIP-014-1,2	Physical Security

NERC CIP V5 Standards



Unprotected Substation LAN Configuration



New NERC Substation LAN Configuration

CONSTRUCTION

- V5 Implementation without service disruptions
- Additional unanticipated upgrades of DC and transport systems had to remain on schedule

CONCLUSION

Upgrading substation hardware for NERC CIP V5 conversions has been complicated by the discovery of legacy and obsolete equipment that must be replaced to enable the required cybersecurity improvements. Another challenge is lack of up to date as-built documentation not adequately representing the current design configuration. Also, the increase in DC power loads from additional substation equipment that is required for V5 may result in the need to upgrade, some batteries, chargers and distribution panels to handle larger capacities. It is recommended that contingencies be included in resource plans, budgets and schedules when beginning the process of modifying substation hardware for NERC CIP standards.